


EXCEPT AS OTHERWISE PROVIDED BY CONTRACT, THIS DRAWING AND SPECIFICATIONS SHALL NOT BE REPRODUCED, COPIED OR USED AS THE BASIS FOR MANUFACTURE OR SALE OF MATTER DEPICTED HEREIN WITHOUT THE EXPRESSED WRITTEN PERMISSION OF THE CLAUDE LAVAL CORPORATION, OR ITS ASSIGNEES.

REVISIONS				
ECN	REV.	DESCRIPTION	DATE	APPROVED

NOTES:

1. OUTLET: 3" FNPT.
2. RATED FLOW: 24-52 gpm (5.5-12 m³/hr).
3. MINIMUM WELL I.D.: 5" (127 mm).
4. MINIMUM SUBMERGENCE: 30 ft (9.2 m)
5. APPROXIMATE DRY WEIGHT: 5.9 lbs (2.7 kg).
6. IF UNIT IS NOT DIRECTLY CONNECTED TO PUMP INTAKE, SHROUD OR PACKERS ARE REQUIRED.

THIS DRAWING HAS BEEN GENERATED AND IS MAINTAINED BY A CAD SYSTEM. CHANGES SHALL ONLY BE INCORPORATED AS DIRECTED BY AN APPROVED ENGINEERING CHANGE ORDER (ECO). PAPER COPIES ARE UNCONTROLLED.



SUBMITTAL DRAWING

This drawing is submitted for spatial consideration only. Do not pre-plumb to these dimensions.

UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN: INCHES [mm] TOLERANCES ARE: FRACTIONS DECIMALS ANGLES $\pm 1"$.XX $\pm .01$ $\pm 1/4^\circ$.XXX $\pm .005$.XXXX $\pm .0005$		ENGINEERED FOR: STANDARD		CLAUDE LAVAL CORP. FRESNO, CALIFORNIA 93727 WWW.LAKOS.COM	
DO NOT SCALE DRAWING		APPROVALS	DATE	TITLE SUB-52, SEPARATOR, SUB-52 TURBINE, ABS/PVC	
MATERIAL ABS/PVC	ENGR -	DRAWN K.F. BITTER	11/1/05	SIZE C	MODEL NO.
FINISH NONE	MFG -	WORK ORDER	QTY.	DWG NO. 125586	REV. 01
SCALE 1:3		EST. WT. 5.9 lb		SHEET 1 OF 1	

DWG. NO. 125586 SHEET 1 REV. 01